



Certification and Testing Service, Inc.

41755 Elm Street, Suite 202

Murrieta, CA 92562

Tel: 951-894-6079 Fax: 951-894-6083

www.CleanroomTestCertification.com

CERTIFICATE OF CERTIFICATION

COMPANY Konicom, Inc. TEST DATE: October 05, 2018
 ADDRESS 1819 J Street
Sacramento, CA 95811 DUE DATE: October 2019
 CLEANROOM/S TESTED Production CER REQUESTOR: Bryan Wu

AIRBORNE PARTICULATE CLEANLINESS CLASS TESTING RESULTS :

	<u>CLASS MET</u>	<u>MICRON</u>	<u>CONDITION</u>
ROOM: <u>PRODUCTION</u>	<u>ISO CLASS 5</u>	<u>0.5, 1.0 & 5.0</u>	<u>At-Rest</u>

TEST EQUIPMENT: Climet Model 750T

CALIBRATION DUE DATE: November 30, 2018

CERTIFIED PER ISO 14644-1:1999(E) CLEANLINESS CLASSIFICATION

Signature of Approval

Date: 10-19-18

CTS Certification and Testing Service, Inc.